



7 August 2020

Flammability of 3M Products

Classification of fire behavior

1.1 Product

Material: 3M™ Solar Window Film Prestige 70
Substrate: Glass

1.2 Commissioned Testing Institute

MPA NRW, Auf den Thränen 2, D-59597 Erwitte

1.3 Classified according to Standard: **DIN EN 13501-1:2010**

Fire classification of construction and building elements

Report of the classification of the reaction to fire performance no. 230011022-3, 13 July 2017

Classification using data from reaction to fire tests.

Testing according to DIN EN ISO 11925-2: Classification report no.: 230011022-1, 13 July 2017

Testing according to DIN EN 13823: Classification report no.: 230011022-2, 13 July 2017.

1.4 With reference to the standard and the present test reports, the company 3M Deutschland GmbH confirms the following resulting overall classification.

B-s1, d0

The product 3M™ Solar Window Film Prestige 70, laminated on glass thus fulfills the requirement set according to the test report result B-s1, d0.

3M Deutschland GmbH
Commercial Solutions Division

Zillikens

This confirmation refers exclusively to the named product combination. The basis are the mentioned test reports of the commissioned test institutes for the classification of the fire behavior. The validity ends when the product or the referring standard is changed.